



Village of Red Hook Wastewater System

		Red Hook Commons			Village of Red Hook	
Average Daily Flow :		0.004 MGD (Million Gallons per Day)			0.040 MGD (Million Gallons per Day)	
		Required Samples	Result			Compliance
<i>June 2024</i>		<i>BOD (June 1 - Oct 31)</i>	2.6 mg/L			5 mg/L
		<i>TSS</i>	6.24 mg/L			10 mg/L
		<i>NH3</i>	0.247			0.98 mg/L (June 1 - Oct 31) 1.81 mg/L (Nov 1 - May 31)
		<i>Fecal Coliform</i>	<1.00/100 mL			200/100 mL
		<i>Dissolved Oxygen</i>	8.0 mg/L			7.0 mg/L Minimum
<u>Deficiencies</u>						
<i>Sand Filter</i>	<i>Sand Filters have never been rebuilt or media replaced. To be reviewed and incorporated into the planning for the Sewer Phase II project.</i>					
<i>Backflow Prev. Replacement</i>	<i>Facilities backflow Preventor in need of replacement.</i>					
<u>Additional Notes:</u>						