

FACILITY MAILING ADDRESS (Street, City, Zip Code)					TELEPHONE NUMBER			CHIEF OPERATOR'S NAME		CERTIFICATION GRADE	
7467 South Broadway; Red Hook, NY 12571					845-758-1081			Robert Flores		4A	
		CBOD(5-Day)(11/1-5/31) BOD (5-Day)(6/1-10/31) [Permit: 5.0 mg/L]		U.O.D. (11/1-5/31) [Permit: 34.0 mg/L]	SUSPENDED SOLIDS [Permit: 10.0 mL/L]		TKN, Total	TOTAL AMMONIA as N [Permit: 6/1-10/31, 0.98 mg/L 11/1-5/31, 1.81 mg/L Effluent mg/L]	FECAL COLIFORM [Permit: 200 No./100 mL] Effluent MF or No./100mL		
DAY	DATE	Influent mg/L	Effluent mg/L	Effluent mg/L	Influent mg/L	Effluent mg/L	Effluent mg/L	Effluent mg/L	Effluent mg/L		
Thu	1										
Fri	2										
Sat	3										
Sun	4										
Mon	5										
Tue	6										
Wed	7										
Thu	8										
Fri	9										
Sat	10										
Sun	11										
Mon	12										
Tue	13										
Wed	14										
Thu	15										
Fri	16										
Sat	17										
Sun	18										
Mon	19										
Tue	20										
Wed	21										
Thu	22										
Fri	23										
Sat	24										
Sun	25										
Mon	26										
Tue	27										
Wed	28		4.6	22.8		10.7	3.54	1.40	<1.00		
Thu	29										
Fri	30										
Sat	31										
		30 day flow-weighted avg ⁽¹⁾			30 day flow-weighted avg ⁽¹⁾				30 day geometric mean ⁽¹⁾		
		inf.(mg/l)	eff.(mg/l)		inf.(mg/l)	eff.(mg/l)		Average			
		#DIV/0!	4.6		#DIV/0!	10.7		1.40	1		
		%Rem.->	#DIV/0!		%Rem.->	#DIV/0!					
30 Day Average								lbs/day			
Quantity Loading ⁽¹⁾		0.76		lbs/day	2		lbs/day	0.23			

(1) Refer to January 1994 edition of DMR Manual for completing the Discharge Monitoring Report for the national Pollutant Discharge Elimination System (NPDES), for procedures to calculate loadings, arithmetic mean, geometric Mean, maximum, minimum, percent removal, etc

NOTE: Refer to current SPDES permit for specific monitoring requirements. Sample type for temperature, PH and settleable solids is grab

