

FACILITY MAILING ADDRESS (Street, City, Zip Code)				TELEPHONE NUMBER		CHIEF OPERATOR'S NAME Leslie A Coon Jr		CERTIFICATION GRADE 3A	
DAY	DATE	TOTAL PHOSPHORUS(mg/l)		Ultraviolet		FECAL COLIFORM		REMARKS Enter any other comments, observations, operating problems, equipment failures, etc.	
		Influent Type	Effluent Type	Contact Minimum	Effluent Maximum	Effluent MF or MPN/100ml			
	1			ON	ON				
	2			ON	ON				
	3			ON	ON				
	4			ON	ON				
	5			ON	ON				
	6			ON	ON		50		
	7			ON	ON				
	8			ON	ON				
	9			ON	ON				
	10			ON	ON				
	11			ON	ON				
	12			ON	ON				
	13			ON	ON				
	14			ON	ON				
	15			ON	ON				
	16			ON	ON				
	17			ON	ON				
	18			ON	ON				
	19			ON	ON				
	20			ON	ON		1		
	21			ON	ON				
	22			ON	ON				
	23			ON	ON				Rome for filter bypassing due to switch accidentally left off
	24			ON	ON				
	25			ON	ON				
	26			ON	ON				
	27			ON	ON				
	28			ON	ON				
	29			ON	ON				
	30			ON	ON				
	31			ON	ON				
		30 day flow-weighted avg mean(1)		Monthly		30 day geometric mean(1)			
		Influent mg/l	Effluent mg/l	Minimum(1)	Maximum(1)				
				ON	ON	7.1			
		lbs/day							

(1) Refer to January 1994 edition of DMR Manual for completing the Discharge Monitoring Report for the national Pollutant Discharge Elimination System (NPDES) for procedures to calculate loadings, arithmetic mean, geometric Mean, maximum, minimum, percent removal, etc
 NOTE: Refer to current SPDES permit for specific monitoring requirements. Sample type for temperature, PH and settleable solids is grab

Day	Date	Fixed Media Process Control								Activated Sludge Process Control						
		NH3 as N		DO		TKN		UOD		Recirculation Rate	Media effluent settleable solids	Mixed Liquor S.S. (MLSS)	Settleable Sludge Volume (SSV) ml/l		Return Act. Sludge (RAS)	Waste Act. Sludge (WAS)
		Influent	Effluent	Influent	Effluent	Influent	Effluent	Influent	Effluent	M.G.D	ml/l	mg/l	5 Minutes	30 minutes	M.G.D.	lbs/day
1					8.2											
2					8.1											
3					8.4											
4					8.8											
5					8.8											
6			0.064		8.6											
7					9.6											
8					9.3											
9					9.0											
10					8.7											
11					8.5											
12					8.7											
13					8.2											
14					8.4											
15					9.8											
16					9.0											
17					8.7											
18					9.0											
19					9.3											
20					9.9		<0.61		<7.10							
21					9.4											
22					9.1											
23					9.4											
24					8.9											
25					8.6											
26					10.5											
27					9.3											
28					9.5											
29					9.2											
30					8.7											
31																
Min:					8.1		<0.61		<7.10							
30 Day Average Quantity					0.064											
Loading (1)					lbs/day		lbs/day		lbs/day							

(1) Refer to January 1994 edition of DMR Manual for completing the Discharge Monitoring Report for the national Pollutant Discharge Elimination System (NPDES) for procedures to calculate loadings, arithmetic mean, geometric Mean, maximum, minimum, percent removal, etc

