

WASTEWATER FACILITY OPERATION REPORT FOR THE MONTH OF: March 2026

SPEDES PERMIT NO.

FACILITY NAME

FACILITY OWNER

FACILITY LOCATION

NY-0271420**Village of Red Hook****same****Red Hook, NY**

DAY	DATE	Daily Precip. in/day	VOLUME OF SEWAGE TREATED			TEMPERATURE (°F)		pH (S.U.)				Settleable Solids (mg/l)		C.B.O.D.5. (mg/l)		Suspended Solids(mg/l)	
			Inst.Max. MGD	Dly Average. MGD	Inst.Min. MGD	Influent (2)	Effluent (2)	Influent Minimum	Influent Maximum	Effluent Minimum	Effluent Maximum	Influent Maximum	Effluent Maximum	Influent Type	Effluent Type	Influent Type	Effluent Type
	1	0.00		0.0256		55.04	51.44	6.50	6.50	7.09	7.09	2.0	<0.1				
	2	0.00		0.0232		50.72	53.6	6.58	6.58	7.06	7.06	<0.1	<0.1				
	3	0.00		0.0243		48.92	50.54	6.64	6.64	7.16	7.16	<0.1	<0.1				
	4	0.00		0.0258		50.7	52.9	6.68	6.68	7.10	7.10	1.0	<0.1				
	5	0.00		0.0266		49.4	53.24	6.54	6.54	7.06	7.06	2.0	<0.1	296	2.6	226	2.4
	6	0.00		0.0292		51.62	53.6			7.06	7.06	<0.1	<0.1				
	7	0.00		0.0263		49.82	52.16	6.59	6.59	7.15	7.15	100	<0.1				
	8	0.00		0.0358		54.1	53.78	6.50	6.50	7.09	7.09	<0.1	<0.1				
	9	0.00		0.0221		49.28	56.12	6.62	6.62	7.18	7.18	34	<0.1				
	10	0.00		0.0248		50.36	53.06	6.74	6.74	7.15	7.15	100	<0.1				
	11	0.00		0.0292		55.22	54.86	6.76	6.76	7.17	7.17	33	<0.1				
	12	0.20		0.0268		56.7	61.9	6.68	6.68	6.96	6.96	25	<0.1				
	13	0.00		0.0279		49.46	52.16	6.57	6.57	7.03	7.03	33	<0.1				
	14	0.00		0.0284		51.08	52.52	6.51	6.51	7.15	7.15	6	<0.1				
	15	0.00		0.0252		50.36	53.2	6.44	6.44	7.03	7.03	<0.1	<0.1				
	16	0.00		0.0265		54.32	54.68	6.59	6.59	7.19	7.19	<0.1	<0.1				
	17	0.00		0.0272		51.98	53.96	6.49	6.49	7.13	7.13	<0.1	<0.1				
	18	0.00		0.0232		57.56	58.4	6.76	6.76	7.10	7.10	2	<0.1				
	19	0.00		0.0267		51.26	52.16	6.61	6.61	7.09	7.09	<0.1	<0.1	243	3.3	191.2	2.2
	20	0.00		0.0323		49.1	50.18	6.49	6.49	7.10	7.10	<0.1	<0.1				
	21	0.00		0.0306		52.16	53.06	6.46	6.46	7.09	7.09	8	<0.1				
	22	0.00		0.0311		54.6	55.9	6.43	6.43	6.97	6.97	1	<0.1				
	23	0.00		0.0287		53.42	53.42	7.05	7.05	7.05	7.05	95	<0.1				
	24	0.00		0.0255		56.84	53.42	6.70	6.70	7.03	7.03	35	<0.1				
	25	0.00		0.0271		54.8	53.9	6.69	6.69	7.03	7.03	18	<0.1				
	26	0.00		0.0301		55.9	61.1	6.57	6.57	7.08	7.08	<0.1	<0.1				
	27	0.00		0.0294		53.6	54.86	6.56	6.56	7.03	7.03	5	<0.1				
	28	0.00		0.0285		51.08	52.7	6.69	6.69	7.09	7.09	2	<0.1				
	29	0.00		0.0251		55.4	57.02	6.66	6.66	6.99	6.99	72.0	<0.1				
	30	0.00		0.0257		56.66	54.68	7.52	7.52	7.11	7.11	7	<0.1				
	31	0.00		0.0267		57.38	59.36	6.62	6.62	7.00	7.00	300	<0.1				
Total Precip. 0.20			Monthly Average			Monthly Maximum		Monthly				Monthly Maximum	Monthly Maximum	30 day flow-weighted avg (1) inf.(mg/l)		30 day flow-weighted avg (1) inf.(mg/l)	
			0.027			57.56	61.90	6.43	7.52	6.96	7.19	300.0	0.0	269	3.0	209	2.3
														%Rem.->	99	%Rem.->	99
Max:			0.0358									30 Day Average Quantity Loading (1)		0.65	lbs/day	1	lbs/day

(1) Refer to January 1994 edition of DMR Manual for completing the Discharge Monitoring Report for the national Pollutant Discharge Elimination System (NPDES) for procedures to calculate loadings, arithmetic mean, geometric Mean, maximum, minimum, percent removal, etc

(2) If Temperature is measured more than once a day, report the average for the day

NOTE: Refer to current SPDES permit for specific monitoring requirements. Sample type for temperature, PH and settleable solids is grab

FACILITY MAILING ADDRESS (Street, City, Zip Code)				TELEPHONE NUMBER		CHIEF OPERATOR'S NAME		CERTIFICATION GRADE
						Leslie A Coon Jr		3A
DAY	DATE	TOTAL PHOSPHORUS(mg/l)		Ultraviolet		FECAL COLIFORM		REMARKS Enter any other comments, observations, operating problems, equipment failures, etc.
		Influent Type	Effluent Type	Contact Minimum	Effluent Maximum	Effluent MF or MPN/100ml		
	1			72.0	72.0			
	2			64.8	64.8			
	3			71.1	71.1			
	4			74.0	74.0			Odor complaint linked to septic truck in area
	5			72.0	72.0		<1.0	
	6			73.0	73.0			
	7			74.0	74.0			
	8			75.0	75.0			
	9			74.0	74.0			
	10			74.0	74.0			
	11			75.0	75.0			
	12			75.0	75.0			
	13			72.0	72.0			
	14			74.0	74.0			
	15			72.0	72.0			
	16			74.0	74.0			
	17			73.0	73.0			
	18			ON	ON			
	19			ON	ON		<1	
	20			ON	ON			
	21			ON	ON			
	22			ON	ON			
	23			ON	ON			
	24			ON	ON			
	25			ON	ON			
	26			ON	ON			
	27			ON	ON			
	28			ON	ON			
	29			ON	ON			
	30			ON	ON			
	31			ON	ON			Odor complaint. Unverifiable at time of inspection. WWTP operating well.
		30 day flow-weighted avg mean(1)		Monthly		30 day geometric mean(1)		
		Influent mg/l	Effluent mg/l	Minimum(1)	Maximum(1)			
				64.8	75.0	<1		
		lbs/day						

(1) Refer to January 1994 edition of DMR Manual for completing the Discharge Monitoring Report for the national Pollutant Discharge Elimination System (NPDES) for procedures to calculate loadings, arithmetic mean, geometric Mean, maximum, minimum, percent removal, etc.

NOTE: Refer to current SPDES permit for specific monitoring requirements. Sample type for temperature, PH and settleable solids is grab

Fixed Media Process Control										Activated Sludge Process Control						
Day	Date	NH3		DO		TKN		UOD		Recirculation Rate	Media effluent settleable solids	Mixed Liquor S.S. (MLSS)	Settleable Sludge Volume (SSV) ml/l		Return Act. Sludge (RAS)	Waste Act. Sludge (WAS)
		Influent	Effluent	Influent	Effluent	Influent	Effluent	Influent	Effluent	M.G.D.	ml/l	mg/l	5 Minutes	30 minutes	M.G.D.	lbs/day
	1				12.1											
	2				14.1											
	3				13.2											
	4				12.6											
	5				11.8											
	6				12.0											
	7				11.3											
	8				11.6											
	9				10.3											
	10		0.959		10.7		3.8		17.10							
	11				10.5											
	12				12.4											
	13				10.6											
	14				10.8											
	15				10.3											
	16				10.1											
	17				11.1											
	18				13.1											
	19		<0.1		12.1		4.15		23.63							
	20				11.2											
	21				10.6											
	22				10.7											
	23				10.1											
	24				11.2											
	25				11.8											
	26				10.7											
	27				9.9											
	28				10.2											
	29				11.3											
	30				10.3											
	31				10.0											
Min:					9.9											
30 Day Average																
Quantity		Max:	0.959			Max:	4.2	Max:	23.63							
Loading (1)		lbs/day		lbs/day		lbs/day		lbs/day								

(1) Refer to January 1994 edition of *DMR Manual for completing the Discharge Monitoring Report for the national Pollutant Discharge Elimination System (NPDES)* for procedures to calculate loadings, arithmetic mean, geometric Mean, maximum, minimum, percent removal, etc

Effect on Receiving Stream

[illegible]

TRUCKED WASTE RECEIVED THIS MONTH

- 1- Septage, holding tank waste and portable toilet waste

Total

Max day

Volume (Gal.)

- 2- All other wastes

Total

Max day

- 3- Number of Part 364 haulers currently approved to transport wastes to this POTW

a. Septage, etc

b. All others

Name and amount of chemicals used in treatment process during month:

a.	gallons
b.	gallons
c.	Gallons
d.	lbs.
e.	Gallons
f.	Gallons

Amount of electrical power consumed:

a. Commercial	_____	kilowatt hours
b. Stand-by	_____	kilowatt hours

Amount of fuel consumed:

a. Natural Gas	cubic feet
b. Oil	gallons
c. Gasoline	gallons
d. Coal	tons
e. Digester Gas	cubic feet
f. propane	gallons

Sludge removal from plant:

a. amount	4000
b. solid content	
c. Volatile Solids Content	
d. Disposal Site:	Superior Sanitation

Other Solid Wastes:

a. Screenings _____

b. Grit _____

c. Ashes _____

d. _____

e. _____

f. _____

g. Disposal Site _____

Digester Gas Wasted

Labor expended:

[illegible]

I hereby affirm under penalty of perjury that information provided on this form is true to the best of my knowledge and belief. False statements made herein are punishable as a Class A misdemeanor pursuant to Section 210.45 of the Penal Law.

Leslie A Coon Jr.

Signature of Chief Operator or Designated Facility Representative

4/14/2026

Date _____