

WASTEWATER FACILITY OPERATION REPORT FOR THE MONTH OF: March 2026

SPEDES PRMIT NO.		FACILITY NAME		FACILITY OWNER		FACILITY LOCATION											
NY-0271420		Village of Red Hook		same		Red Hook, NY											
DAY	DATE	Daily Precip. in/day	VOLUME OF SEWAGE TREATED		TEMPERATURE (°F)		pH (S.U.)		Settleable Solids (mg/l)		C.B.O.D.5. (mg/l)		Suspended Solids(mg/l)				
			Inst.Max. MGD	Dly Average. MGD	Inst.Min. MGD	Influent (2)	Effluent (2)	Influent Minimum	Influent Maximum	Effluent Minimum	Effluent Maximum	Influent Maximum	Effluent Maximum	Influent Type	Effluent Type	Influent Type	Effluent Type
	1	0.00		0.010		53.6	62.06	7.61	7.61	7.85	7.85	4.0	<0.1				
	2	0.00		0.008		57.38	57.74	7.59	7.59	7.29	7.29	1	<0.1				
	3	0.00		0.007		54.14	61.7	7.57	7.57	7.22	7.22	<0.1	<0.1				
	4	0.00		0.010		52.3	53.2	7.67	7.67	7.84	7.84	15.0	<0.1				
	5	0.00		0.008		52.1	53.9	7.91	7.91	7.65	7.65	8.5	<0.1	201	5.2	276	6.4
	6	0.00		0.008		52.7	53.06	7.77	7.77	7.48	7.48	12	<0.1				
	7	0.00		0.007		55.04	55.22	7.71	7.71	7.36	7.36	12	<0.1				
	8	0.00		0.009		55.1	56.1	7.69	7.69	7.67	7.67	<0.1	<0.1				
	9	0.00		0.003		56.48	56.66	7.24	7.24	7.32	7.32	24	<0.1				
	10	0.00		0.003		55.22	57.92	7.40	7.40	7.43	7.43	2	<0.1				
	11	0.00		0.004		57.2	59	7.63	7.63	7.73	7.73	8	<0.1				
	12	0.20		0.008		58.1	59.4	7.63	7.63	7.29	7.29	7	<0.1				
	13	0.00		0.010		57.2	68.46	7.32	7.32	7.27	7.27	11	<0.1				
	14	0.00		0.011		54.86	55.4	7.60	7.60	7.27	7.27	34	<0.1				
	15	0.00		0.008		51.09	54.3	7.66	7.66	7.70	7.70	14	<0.1				
	16	0.00		0.006		55.22	59.72	7.74	7.74	7.71	7.71	11	<0.1				
	17	0.00		0.009		56.48	59.9	7.44	7.44	7.52	7.52	2.5	<0.1				
	18	0.00		0.006		54.8	57.2	7.63	7.63	7.85	7.85	3	<0.1				
	19	0.00		0.005		52.1	52.8	7.70	7.70	7.54	7.54	2.0	<0.1	179	2.5	220.5	4.8
	20	0.00		0.011		55.4	56.48	7.64	7.64	7.38	7.38	20	<0.1				
	21	0.00		0.006		56.48	56.12	7.53	7.53	7.30	7.30	25	<0.1				
	22	0.00		0.005		55.04	56.3	7.60	7.60	7.81	7.81	2	<0.1				
	23	0.00		0.009		56.84	58.1	7.46	7.46	7.28	7.28	14	<0.1				
	24	0.00		0.006		56.84	58.1	7.56	7.56	7.20	7.20	24	<0.1				
	25	0.00		0.005		55	59.1	7.39	7.39	7.67	7.67	2	<0.1				
	26	0.00		0.004		55.5	57.3	7.45	7.45	7.70	7.70	<0.1	<0.1				
	27	0.00		0.010		57.38	57.02	7.33	7.33	7.29	7.29	8	<0.1				
	28	0.00		0.007		54.8	61.7	7.30	7.30	7.34	7.34	2	<0.1				
	29	0.00		0.004		57.5	55.4	7.47	7.47	7.68	7.68	<0.1	<0.1				
	30	0.00		0.011		59.36	58.46	7.51	7.51	7.24	7.24	25	<0.1				
	31	0.00		0.009		59.9	61.16	7.31	7.31	7.17	7.17	56	<0.1				
Total Precip. 0.20		Monthly Average 0.007		Monthly Maximum Influent Effluent 59.90 68.46		Minimum 7.24	Maximum 7.91	Monthly Minimum 7.17	Maximum 7.85	Monthly Maximum 56.0	Monthly Maximum <0.1	30 day flow-weighted avg (1) inf.(mg/l) eff.(mg/l) 192 4.1		30 day flow-weighted avg (1) inf.(mg/l) eff.(mg/l) 253 5.7			
Max:		0.011								30 Day Average Quantity Loading (1)		0.22		lbs/day		0 lbs/day	

(1) Refer to January 1994 edition of DMR Manual for completing the Discharge Monitoring Report for the national Pollutant Discharge Elimination System (NPDES) for procedures to calculate loadings, arithmetic mean, geometric Mean, maximum, minimum, percent removal, etc

(2) If Temperature is measured more than once a day, report the average for the day

NOTE: Refer to current SPDES permit for specific monitoring requirements. Sample type for temperature, PH and settleable solids is grab

FACILITY MAILING ADDRESS (Street, City, Zip Code)				TELEPHONE NUMBER		CHIEF OPERATOR'S NAME Leslie A Coon Jr		CERTIFICATION GRADE 3A	
DAY	DATE	TOTAL PHOSPHORUS(mg/l)		Ultraviolet		FECAL COLIFORM		REMARKS Enter any other comments, observations, operating problems, equipment failures, etc.	
		Influent Type	Effluent Type	Contact Minimum	Effluent Maximum	Effluent MF or MPN/100ml			
	1			69.5	100.0				
	2			32.6	100.0				
	3			34.7	100.0				
	4			64.0	100.0				
	5			71.0	100.0		<1		
	6			46.2	100.0				
	7			41.5	100.0				
	8			47.0	100.0				
	9			37.8	100.0				
	10			39.6	100.0				
	11			93.4	100.0				
	12			54.6	100.0				
	13			51.4	100.0				
	14			44.3	100.0				
	15			61.7	100.0				
	16			60.1	100.0				
	17			33.3	100.0				
	18			48.6	100.0				
	19			62.0	100.0		<1		
	20			41.0	100.0				
	21			41.0	100.0				
	22			55.0	100.0				
	23			50.9	100.0				
	24			29.6	100.0				
	25			45.2	100.0				
	26			48.0	100.0				
	27			27.6	100.0				
	28			26.0	100.0				
	29			37.0	100.0				
	30			21.5	100.0				
	31			21.3	100.0				
		30 day flow-weighted avg mean(1) Influent mg/l Effluent mg/l		Monthly Minimum(1) Maximum(1)		30 day geometric mean(1)			
				21.3 100.0		<1			
		lbs/day 							

(1) Refer to January 1994 edition of *DMR Manual for completing the Discharge Monitoring Report for the national Pollutant Discharge Elimination System (NPDES)* for procedures to calculate loadings, arithmetic mean, geometric Mean, maximum, minimum, percent removal, etc

NOTE: Refer to current SPDES permit for specific monitoring requirements. Sample type for temperature, PH and settleable solids is grab

Fixed Media Process Control										Activated Sludge Process Control							
Day	Date	NH3		DO		TKN		UOD		Recirculation Rate M.G.D	Media effluent settleable solids ml/l	Mixed Liquor S.S. (MLSS) mg/l	Settleable Sludge Volume (SSV) ml/l		Return Act. Sludge (RAS) M.G.D.	Waste Act. Sludge (WAS) lbs/day	
		Influent	Effluent	Influent	Effluent	Influent	Effluent	Influent	Effluent				5 Minutes	30 minutes			
	1				11.9												
	2				13.1												
	3				12.2												
	4				12.1												
	5		0.3		11.7		2.6		19.50								
	6				11.1												
	7				10.7												
	8				10.4												
	9				10.1												
	10				10.2												
	11				10.1												
	12				11.4												
	13				9.6												
	14				10.3												
	15				10.3												
	16				9.9												
	17				10.6												
	18				12.9												
	19		<0.1		11.6		3.84		21.03								
	20				11.0												
	21				10.2												
	22				10.2												
	23				9.9												
	24				10.7												
	25				11.4												
	26				11.1												
	27				9.8												
	28				10.2												
	29				11.6												
	30				10.4												
	31				10.0												
Min:					9.6												
30 Day Average Quantity		MAX:	0.3			MAX:	3.84	Max:	21.03								
Loading (1)		lbs/day		lbs/day		lbs/day		lbs/day									

(1) Refer to January 1994 edition of *DMR Manual for completing the Discharge Monitoring Report for the national Pollutant Discharge Elimination System (NPDES)* for procedures to calculate loadings, arithmetic mean, geometric Mean, maximum, minimum, percent removal, etc.

Effect on Receiving Stream

[illegible]

TRUCKED WASTE RECEIVED THIS MONTH

- | | | | |
|----|---|--|---------|
| 1- | Septage, holding tank waste and portable toilet waste | | |
| | Total | | Max day |

Volume (Gal.)			
2-	All other wastes		
		Total	Max day

- 3- Number of Part 364 haulers currently approved to transport wastes to this POTW

a. Septage, etc

b. All others

Name and amount of chemicals used in treatment process

during month:

- | | |
|----|---------|
| a. | gallons |
| b. | gallons |
| c. | Gallons |
| d. | lbs. |
| e. | Gallons |
| f. | Gallons |

Amount of electrical power consumed:

- | | | |
|---------------|-------|----------------|
| a. Commercial | _____ | kilowatt hours |
| b. Stand-by | _____ | kilowatt hours |

Amount of fuel consumed:

- | | |
|-----------------|------------|
| a. Natural Gas | cubic feet |
| b. Oil | gallons |
| c. Gasoline | gallons |
| d. Coal | tons |
| e. Digester Gas | cubic feet |
| f. propane | gallons |

Sludge removal from plant:

- a. amount _____
b. solid content _____
c. Volatile Solids Content _____
d. Disposal Site: _____

Other Solid Wastes:

- a. Screenings _____
- b. Grit _____
- c. Ashes _____
- d. _____
- e. _____
- f. _____
- g. Disposal Site _____

Digester Gas Wasted

Labor expended:

[illegible]

I hereby affirm under penalty of perjury that information provided on this form is true to the best of my knowledge and belief. False statements made herein are punishable as a Class A misdemeanor pursuant to Section 210.45 of the Penal Law

Leslie A Coon Jr.

Signature of Chief Operator or Designated Facility Representative

4/14/2026

Date _____